



STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



2 of 2

**Violations Comments**

Violation #5. Maintenance & Repair  
Observed burnt-out light bulbs in the following areas: Art lab (14ft-candles), room 1011 (13ft-candles), music room (23ft-candles). Replace burnt-out light bulbs and reach minimum illumination of 40ft-candles.

Observed missing light cover in bathroom 17308. Provide cover for light fixture.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #14. Soap Dispensers

Observed missing soap dispensers in the following bathrooms: boy's 17039, girl's 17038, 1009 girl's, and 1010 boy's. Provide soap dispensers.

CODE REFERENCE: 14. Soap Dispensers. 468.3.5.7.2 FBC. Soap dispensers for liquid, foam or powdered soap shall be provided at all handwashing basins. 5(10)(f) SREF. Dispensers for liquid, foam, or powdered soap shall be maintained in a safe & secure condition at all times.

Inspection Conducted By: Raad Farhang (913251)  
Inspector Contact Number: Work: (305) 623-3575 ex.  
Print Client Name: Deborah Darbonne  
Date: 3/6/2024

Inspector Signature:

Handwritten signature of Raad Farhang.

Client Signature:

Handwritten signature of Deborah Darbonne.